

LPG 100 lb & Liquid Fuel Fires – Hands On Checklist

(For Hosting Agency)

Safe & Secure Training Ground need a solid backing to place LPG 100 lb prop and/or Liquid Fuel Fire Pan so that students can safely direct and spray various streams/patterns in the direction of the staged prop(s).

Minimum of (2) Pumper Firetrucks (1250 GPM Minimum) to be dedicated to & utilized for the training.

2000 Gallon of Water in reserve (Dump Tank or Tanker) to be dedicated and utilized for the training.

Live Fire Competency Forms completed for each Firefighter/Student participating in the training.

Form of Identification (an official form) to verify identity and age.

Firefighting PPE within 10 years of manufacture date; NFPA 1851.

Compliance with OSHA 1910.134 (No Facial Hair impeding facepiece sealing surface)

Minimum of 10 Students PARTICIPATING in Hands On portion of training.

No Camera or Recording Device inside of the Operational Zone for Live Fire Training. The Operational Zone shall be set forth by the Lead Instructor and enforced by any Instructor and/or attendee.